



Certificate of Completion

Duct Sealing Performed for:
Sal Dimiceli West
1856 Inlet Drive
North fort myers, FL 33903
(239)574-1247

Overall Sealing Results

When we arrived,
YOUR DUCTS HAD:

210 CFM of Leakage, equivalent to a
40 Square Inch Hole


After we finished,
YOUR DUCTS HAVE:

6 CFM of Leakage, equivalent to a
1 Square Inch Hole

This corresponds to a **97% Reduction** in Duct Leakage

Note: Duct leakage results are calculated in cubic feet per minute (CFM) measured at a standard OPERATING PRESSURE of 25 Pa (0.10 in. water).

Aerosol Sealing Profile



Your Heating and Cooling Capacity Improvement for Duct Sealing is **16%** based upon measured leakage reduction and original register flow



Aeroseal Technician: Bill R
Aeroseal Equipment Serial #: 2534
Wednesday, March 26, 2014